



BTU METERING SHALL BE BY H2O DEGREE AND SHALL INCLUDE (1) H2O DEGREE PART NUMBER M53131-KIT WITH INTEGRATED RADIO TRANSMITTER PER DWELLING UNIT. THE H2O DEGREE GATEWAY AND COORDINATOR SHALL BE LOCATED IN THE PROPERTY OFFICE OR IN THE CLUBHOUSE. MECHANICAL CONTRACTOR IS TO COORDINATE LOCATION OF POWER SERVICES FOR BTU METERS (24 VAC POWERED) AND REPEATERS (IF REQUIRED) AND GATEWAY WITH THE ELECTRICAL CONTRACTOR. ALL EQUIPMENT SHALL BE PROVIDED UNDER THE MECHANICAL CONTRACT UNLESS DIRECTED OTHERWISE BY THE OWNER OR GENERAL CONTRACTOR.

NOTE V1000 AND RTD1003 CAN ALSO BE INSTALLED IN A FREE FLOWING LOOP SYSTEM WITHOUT AN ACTUATED VALVE. BTU METER HAS NO MECHANICAL PARTS AFFECTED BY FLOW TIME.