



H2O Degree Thermostat Cool Diagnostic Report for 360 State Street

Prepared at **09/18/2015 15:45:17**

Cool Diagnostic Message occurs if

- (1) Thermostat is in COOL Mode for 24 hours
- (2) COOL run time is at least 22 hours out of 24 hours

Room temperature below normal occurs if

- (1) Thermostat is in COOL mode for 24 hours
- (2) Thermostat measures the hour average room temperature above 68 degrees F more than 18 hours in any one day

COOL Diagnostic

Building	Apartment	Serial #	Location	1 day COOL run time
30	3002	00C0270001000B50	HVAC-Hallway 3002	1380
30	3008	00C0270001000B87	HVAC-Bedroom 3008	1380
30	3008	00C0270001000B7A	HVAC-Hallway 3008	1380

Room Temperature below normal

Building	Apartment	Serial #	Location	Hourly average room temperature
06	Game Room	00C0270001000A75	HVAC-East Game Room	66
16	1613	00C0270001000384	HVAC-Bedroom 1613	67
09	919	00C0270001000824	HVAC-Living Room 919	67
30	3008	00C0270001000B87	HVAC-Bedroom 3008	66
14	1403	00C0270001000121	HVAC-Living Room 1403	67
19	1922	00C0270001000967	HVAC-Hallway 1922	65

COOL Diagnostic Details

COOL Diagnostic Details for [00C0270001000B50](#)

Building	Apartment	Serial #	Location	1 day COOL run time
30	3002	00C0270001000B50	HVAC-Hallway 3002	1380

date time	mode	outdoor temp	room temp	cool setpoint	cool runtime (mins)
09/16/2015 23:52:45	COOL	67	71.6	69	-