



H2O Degree Toilet Diagnostic Report - Pomeroy

Prepared Jan 14 2016 2:45AM

Gallons Per Event Threshold : 8
Events Per Day Threshold : 50
Single Day High Use Threshold : 150
Gallons Used with No Events Threshold : 10

This toilet diagnostic report uses the above four criteria in order to determine if a toilet is leaking. One toilet can fail one or more of the criteria. The table of content the most important part of the toilet diagnostic report. The Toilet Diagnostic Report is designed to be viewed using a browser. The table of contents shown below all the user to click on the View link in order to see the last 30 days of data for any toilet on the diagnostic report. The historical 30 day data is shown on the report so that user can look for recurring problems over the last 30 days.

HINT: Use the table of contents to determine the toilets with the largest 30 day consumption and repair those toilets first.

Table of Contents

Building	Apt	Serial #	Location	Water Last 30 Days	Events Last 30 Days	Gallons Per Event	Events Per Day	Single Day High Use	Use with No Events
6705 S Lewis Ave	129	000D6F0004AD84BC	Half Bath toilet	69925	..	View		View	
6841 S Lewis Ave	079	000D6F0005029DDF	Full Bath Toilet	18486	..	View		View	
6821 S Lewis Ave	041	000D6F0004C9C26E	Full Bath Toilet	7287	8797		View	View	
6805 S Lewis Ave	009	000D6F0005408000	Full Bath Toilet	6556	8143		View	View	
6855 S Lewis Ave	107	000D6F0005407FFF	Full Bath Toilet	4732	..			View	View
6805 S Lewis Ave	009	000D6F0004C9D2FC	Half Bath toilet	2504	..			View	
6719 S Lewis Ave	157	000D6F0005409E4B	Full Bath Toilet	2256	3401		View		
6807 S Lewis Ave	014	000D6F000542F33E	Full Bath Toilet	1244	..	View			

Gallons Per Event

High Consumption - High Gallons Per Events - This is seen as a continuous flow - where a flow event just runs on for hours, driving up the average gallons per flow event. The most frequent cause is a toilet fill valve failure, or a toilet flapper chain hanging up, causing the flapper to remain open. This last condition is hard to diagnose because it occurs intermittently. One such event will consume water at 3 gallons per minute. A flapper valve held open for 2 days (48 hours) may consume 9,000 gallons. Average use of an apartment is only 2,000 to 3,000 gallons a month.

Gallons Per Event

Property	Building	Apt	Serial #	Location	Gallons Per Event	
Pomeroy	6705 S Lewis Ave	129	000D6F0004AD84BC	Half Bath toilet	3709.9	
Read Date	Current Water Register(Gallons)	Avg Gallons Per Event	Usage Since Last Report (Gallons)	Event Register (Cumulative)	Events Since Last Report	Reported?
Jan 14 2016 2:10AM	113822	3709.9	7420	1406	2	Yes
Jan 13 2016 2:09AM	106402	97.3	1459	1404	15	Yes
Jan 12 2016 2:08AM	104943	3371.4	6743	1389	2	Yes
Jan 11 2016 2:05AM	98200	505.9	1012	1387	2	Yes
Jan 10 2016 2:06AM	97188	0.0	1171	1385	0	Yes
Jan 9 2016 2:08AM	96018	0.0	0	1385	0	Yes
Jan 8 2016 2:08AM	96018	4.6	9	1385	2	Yes
Jan 7 2016 2:09AM	96008	4.7	9	1383	2	Yes
Jan 6 2016 2:08AM	95999	0.6	19	1381	31	Yes
			Total : 69925			

Property	Building	Apt	Serial #	Location	Gallons Per Event	
Jan 5 2016 2:08AM	95980	4.6	485	1350	105	Yes
Jan 4 2016 2:07AM	95495	923.9	4619	1245	5	Yes
Jan 3 2016 2:09AM	90875	52.7	2002	1240	38	Yes
Jan 2 2016 2:07AM	88873	6007.3	6007	1202	1	Yes
Jan 1 2016 2:07AM	82866	1041.9	1042	1201	1	Yes
Dec 31 2015 2:07AM	81824	5425.5	5426	1200	1	Yes
Dec 30 2015 2:08AM	76398	256.4	3333	1199	13	Yes
Dec 29 2015 2:03AM	73065	13.6	1724	1186	127	Yes
Dec 28 2015 2:02AM	71341	1005.5	2011	1059	2	Yes
Dec 27 2015 2:05AM	69330	0.0	0	1057	0	Yes
Dec 26 2015 2:02AM	69330	4.7	5	1057	1	Yes
Dec 25 2015 2:08AM	69326	6514.2	6514	1056	1	Yes
Dec 24 2015 2:05AM	62812	653.3	3920	1055	6	Yes
Dec 23 2015 2:05AM	58892	0.0	7978	1049	0	Yes
Dec 22 2015 2:04AM	50914	0.0	2953	1049	0	Yes
Dec 21 2015 2:03AM	47961	75.5	2795	1049	37	Yes
Dec 20 2015 2:03AM	45167	0.0	1248	1012	0	Yes
Dec 19 2015 2:04AM	43918	3.3	7	1012	2	Yes
Dec 18 2015 2:05AM	43912	4.7	5	1010	1	Yes
Dec 17 2015 2:06AM	43907	4.6	9	1009	2	Yes
Dec 16 2015 2:04AM	43898	1007	...	Yes
			Total : 69925			

Gallons Per Event

Property	Building	Apt	Serial #	Location	Gallons Per Event	
Pomeroy	6807 S Lewis Ave	014	000D6F000542F33E	Full Bath Toilet	14.2	
Read Date	Current Water Register(Gallons)	Avg Gallons Per Event	Usage Since Last Report (Gallons)	Event Register (Cumulative)	Events Since Last Report	Reported?
Jan 14 2016 2:10AM	7770	14.2	85	6471	6	Yes
Jan 13 2016 2:09AM	7685	3.2	45	6465	14	Yes
Jan 12 2016 2:08AM	7640	2.4	14	6451	6	Yes
Jan 11 2016 2:05AM	7626	11.5	332	6445	29	Yes
Jan 10 2016 2:06AM	7293	2.6	29	6416	11	Yes
Jan 9 2016 2:08AM	7264	2.1	32	6405	15	Yes
Jan 8 2016 2:08AM	7232	2.2	31	6390	14	Yes
Jan 7 2016 2:09AM	7201	1.8	31	6376	17	Yes
Jan 6 2016 2:08AM	7171	2.3	26	6359	11	Yes
Jan 5 2016 2:08AM	7145	2.2	42	6348	19	Yes
Jan 4 2016 2:07AM	7102	2.1	15	6329	7	Yes
Jan 3 2016 2:09AM	7088	2.1	49	6322	24	Yes
Jan 2 2016 2:07AM	7038	1.9	11	6298	6	Yes
Jan 1 2016 2:07AM	7027	1.8	35	6292	19	Yes
Dec 31 2015 2:07AM	6992	2.3	25	6273	11	Yes
Dec 30 2015 2:08AM	6967	2.9	46	6262	16	Yes
Dec 29 2015 2:03AM	6921	1.4	7	6246	5	Yes
Dec 28 2015 2:02AM	6914	2.2	47	6241	21	Yes
Dec 27 2015 2:05AM	6867	2.3	7	6220	3	Yes
Dec 26 2015 2:02AM	6860	3.9	82	6217	21	Yes
Dec 25 2015 2:08AM	6778	1.5	9	6196	6	Yes
Dec 24 2015 2:05AM	6769	2.4	38	6190	16	Yes
Dec 23 2015 2:05AM	6732	0.7	81	6174	122	Yes
Dec 22 2015 2:04AM	6650	1.7	21	6052	12	Yes
Dec 21 2015 2:03AM	6630	2.2	15	6040	7	Yes
Dec 20 2015 2:03AM	6614	2.1	30	6033	14	Yes
Dec 19 2015 2:04AM	6585	2.6	13	6019	5	Yes
Dec 18 2015 2:05AM	6572	2.1	27	6014	13	Yes
Dec 17 2015 2:06AM	6545	2.2	19	6001	9	Yes
Dec 16 2015 2:04AM	6525	5992	...	Yes
			Total : 1244			

Gallons Per Event

Property	Building	Apt	Serial #	Location	Gallons Per Event	
Pomeroy	6841 S Lewis Ave	079	000D6F0005029DDF	Full Bath Toilet	86.0	
Read Date	Current Water Register(Gallons)	Avg Gallons Per Event	Usage Since Last Report (Gallons)	Event Register (Cumulative)	Events Since Last Report	Reported?
Jan 14 2016 2:10AM	72001	86.0	688	54413	8	Yes
Jan 13 2016 2:09AM	71314	16.6	1065	54405	64	Yes
Jan 12 2016 2:08AM	70249	8.5	416	54341	49	Yes
Jan 11 2016 2:05AM	69833	4.1	410	54292	101	Yes
Jan 10 2016 2:06AM	69423	0.1	58	54191	461	Yes
Jan 9 2016 2:08AM	69364	0.2	1	53730	3	Yes
Jan 8 2016 2:08AM	69364	7.3	15	53727	2	Yes
Jan 7 2016 2:09AM	69349	7.9	32	53725	4	Yes
Jan 6 2016 2:08AM	69317	158.1	316	53721	2	Yes
Jan 5 2016 2:08AM	69001	0.0	1416	53719	0	Yes
Jan 4 2016 2:07AM	67586	62.0	496	53719	8	Yes
Jan 3 2016 2:09AM	67090	33.8	1452	53711	43	Yes
Jan 2 2016 2:07AM	65638	0.0	632	53668	0	Yes
Jan 1 2016 2:07AM	65006	9.9	897	53668	91	Yes
Dec 31 2015 2:07AM	64109	0.0	691	53577	0	Yes
Dec 30 2015 2:08AM	63418	78.9	1104	53577	14	Yes
Dec 29 2015 2:03AM	62314	2.6	428	53563	165	Yes
Dec 28 2015 2:02AM	61886	770.6	1541	53398	2	Yes
Dec 27 2015 2:05AM	60345	0.0	583	53396	0	Yes
Dec 26 2015 2:02AM	59762	10.0	736	53396	74	Yes
Dec 25 2015 2:08AM	59026	2.8	285	53322	103	Yes
Dec 24 2015 2:05AM	58740	104.3	939	53219	9	Yes
Dec 23 2015 2:05AM	57801	10.7	386	53210	36	Yes
Dec 22 2015 2:04AM	57415	1.4	639	53174	457	Yes
Dec 21 2015 2:03AM	56776	7.1	21	52717	3	Yes
Dec 20 2015 2:03AM	56755	720.1	720	52714	1	Yes
Dec 19 2015 2:04AM	56035	0.0	755	52713	0	Yes
Dec 18 2015 2:05AM	55279	268.0	1340	52713	5	Yes
Dec 17 2015 2:06AM	53939	14.1	424	52708	30	Yes
Dec 16 2015 2:04AM	53515	52678	...	Yes
			Total : 18486			

Events Report

High Events - Flapper Leak - When flappers leak, they allow the toilet tank to slowly leak into the bowl (and through to the sewer), then the tank re-fills sudden and this process is repeated so often that it impacts average gallons per flow event, driving the value down until it appears in this diagnostic field

Events Per Day

Property	Building	Apt	Serial #	Location	Events Per Day
Pomeroy	6719 S Lewis Ave	157	000D6F0005409E4B	Full Bath Toilet	51.0
Read Date	Event Register (Cumulative)	Events Per Report Interval	Current Water Register (Gallons)	Usage Since Last Report (Gallons)	Reported?
Jan 14 2016 2:10AM	4542	51	5539	65	Yes
Jan 13 2016 2:09AM	4491	23	5474	32	Yes
Jan 12 2016 2:08AM	4468	42	5442	43	Yes
Jan 11 2016 2:05AM	4426	7	5399	3	Yes
Jan 10 2016 2:06AM	4419	50	5396	75	Yes
Jan 9 2016 2:08AM	4369	20	5321	21	Yes
Jan 8 2016 2:08AM	4349	39	5300	49	Yes
		Total Events : 3401		Total Gallons : 2256	

Property	Building	Apt	Serial #	Location	Events Per Day
Jan 7 2016 2:09AM	4310	10	5251	9	Yes
Jan 6 2016 2:08AM	4300	49	5242	68	Yes
Jan 5 2016 2:08AM	4251	20	5174	21	Yes
Jan 4 2016 2:07AM	4231	36	5153	37	Yes
Jan 3 2016 2:09AM	4195	31	5116	44	Yes
Jan 2 2016 2:07AM	4164	38	5073	40	Yes
Jan 1 2016 2:07AM	4126	18	5033	9	Yes
Dec 31 2015 2:07AM	4108	58	5023	66	Yes
Dec 30 2015 2:08AM	4050	33	4957	27	Yes
Dec 29 2015 2:03AM	4017	49	4930	30	Yes
Dec 28 2015 2:02AM	3968	26	4900	22	Yes
Dec 27 2015 2:05AM	3942	63	4878	44	Yes
Dec 26 2015 2:02AM	3879	21	4834	22	Yes
Dec 25 2015 2:08AM	3858	41	4812	38	Yes
Dec 24 2015 2:05AM	3817	17	4774	10	Yes
Dec 23 2015 2:05AM	3800	37	4764	43	Yes
Dec 22 2015 2:04AM	3763	183	4721	74	Yes
Dec 21 2015 2:03AM	3580	143	4647	364	Yes
Dec 20 2015 2:03AM	3437	574	4283	190	Yes
Dec 19 2015 2:04AM	2863	719	4093	308	Yes
Dec 18 2015 2:05AM	2144	534	3785	137	Yes
Dec 17 2015 2:06AM	1610	469	3648	365	Yes
Dec 16 2015 2:04AM	1141	...	3283	...	Yes
		Total Events : 3401			Total Gallons : 2256

Events Per Day

Property	Building	Apt	Serial #	Location	Events Per Day
Pomeroy	6805 S Lewis Ave	009	000D6F0005408000	Full Bath Toilet	201.0
Read Date	Event Register (Cumulative)	Events Per Report Interval	Current Water Register (Gallons)	Usage Since Last Report (Gallons)	Reported?
Jan 14 2016 2:10AM	43607	201	32631	165	Yes
Jan 13 2016 2:09AM	43406	396	32466	327	Yes
Jan 12 2016 2:08AM	43010	200	32139	165	Yes
Jan 11 2016 2:05AM	42810	394	31974	327	Yes
Jan 10 2016 2:06AM	42416	197	31647	164	Yes
Jan 9 2016 2:08AM	42219	404	31484	327	Yes
Jan 8 2016 2:08AM	41815	201	31156	164	Yes
Jan 7 2016 2:09AM	41614	401	30992	330	Yes
Jan 6 2016 2:08AM	41213	202	30663	162	Yes
Jan 5 2016 2:08AM	41011	408	30501	326	Yes
Jan 4 2016 2:07AM	40603	207	30175	164	Yes
Jan 3 2016 2:09AM	40396	410	30011	325	Yes
Jan 2 2016 2:07AM	39986	196	29686	163	Yes
Jan 1 2016 2:07AM	39790	414	29523	326	Yes
Dec 31 2015 2:07AM	39376	207	29197	164	Yes
Dec 30 2015 2:08AM	39169	413	29033	328	Yes
Dec 29 2015 2:03AM	38756	210	28705	163	Yes
Dec 28 2015 2:02AM	38546	410	28542	326	Yes
Dec 27 2015 2:05AM	38136	202	28216	162	Yes
Dec 26 2015 2:02AM	37934	420	28054	321	Yes
Dec 25 2015 2:08AM	37514	207	27734	161	Yes
Dec 24 2015 2:05AM	37307	406	27572	326	Yes
Dec 23 2015 2:05AM	36901	201	27246	160	Yes
Dec 22 2015 2:04AM	36700	396	27087	318	Yes
Dec 21 2015 2:03AM	36304	210	26768	158	Yes
Dec 20 2015 2:03AM	36094	404	26611	322	Yes
Dec 19 2015 2:04AM	35690	139	26289	140	Yes
Dec 18 2015 2:05AM	35551	87 (1)	26149	72 (1)	Yes
Dec 17 2015 2:06AM	35464	0	26077	0	No
		Total Events : 8143			Total Gallons : 6556

Property	Building	Apt	Serial #	Location	Events Per Day
Dec 16 2015 2:04AM	35464	...	26077	...	Yes
			Total Events : 8143	Total Gallons : 6556	

Note 1: This value is an accumulation of multiple days worth of data due to a non reporting device. A yellow line in the above table indicates that the radio attached to this toilet did not report. This is normal. Although the radio did not report the water meter still measured and recorded the gallons and events.

Note 2: This is the first report from this device. Data is cumulative since install. These values are not used in totals. An orange line in the above table indicates that the radio attached to this toilet is was provisioned but never reported. This is normal. Although the radio did not report the water meter still measured and recorded the gallons and events.

Events Per Day

Property	Building	Apt	Serial #	Location	Events Per Day
Pomeroy	6821 S Lewis Ave	041	000D6F0004C9C26E	Full Bath Toilet	394.0
Read Date	Event Register (Cumulative)	Events Per Report Interval	Current Water Register (Gallons)	Usage Since Last Report (Gallons)	Reported?
Jan 14 2016 2:10AM	40102	394	31282	335	Yes
Jan 13 2016 2:09AM	39708	195	30947	162	Yes
Jan 12 2016 2:08AM	39513	378	30786	325	Yes
Jan 11 2016 2:05AM	39135	186	30460	162	Yes
Jan 10 2016 2:06AM	38949	398	30299	331	Yes
Jan 9 2016 2:08AM	38551	196	29967	165	Yes
Jan 8 2016 2:08AM	38355	386	29802	330	Yes
Jan 7 2016 2:09AM	37969	190	29472	164	Yes
Jan 6 2016 2:08AM	37779	400	29308	336	Yes
Jan 5 2016 2:08AM	37379	195	28972	167	Yes
Jan 4 2016 2:07AM	37184	397	28805	330	Yes
Jan 3 2016 2:09AM	36787	195	28476	163	Yes
Jan 2 2016 2:07AM	36592	409	28313	326	Yes
Jan 1 2016 2:07AM	36183	199	27987	166	Yes
Dec 31 2015 2:07AM	35984	405	27821	331	Yes
Dec 30 2015 2:08AM	35579	202	27489	170	Yes
Dec 29 2015 2:03AM	35377	405	27320	336	Yes
Dec 28 2015 2:02AM	34972	195	26983	166	Yes
Dec 27 2015 2:05AM	34777	378	26817	328	Yes
Dec 26 2015 2:02AM	34399	204	26489	168	Yes
Dec 25 2015 2:08AM	34195	410	26321	332	Yes
Dec 24 2015 2:05AM	33785	202	25989	164	Yes
Dec 23 2015 2:05AM	33583	405	25824	332	Yes
Dec 22 2015 2:04AM	33178	206	25492	162	Yes
Dec 21 2015 2:03AM	32972	411	25330	335	Yes
Dec 20 2015 2:03AM	32561	210	24996	164	Yes
Dec 19 2015 2:04AM	32351	415	24831	333	Yes
Dec 18 2015 2:05AM	31936	211	24499	169	Yes
Dec 17 2015 2:06AM	31725	420	24329	335	Yes
Dec 16 2015 2:04AM	31305	...	23994	...	Yes
		Total Events : 8797		Total Gallons : 7287	

Single Day High Use

High Consumption - High Gallons Per Day - Toilets that use more than 150 gallons are suspected of leaking. The most frequent cause is a toilet fill valve failure, a toilet flapper chain hanging up, causing the flapper to remain open. This last condition is hard to diagnose because it occurs intermittently. One such event will consume water at 3 gallons per minute. A flapper valve held open for 2 days (48 hours) may consume 9,000 gallons. Average use of an apartment is only 2,000 to 3,000 gallon month.

Single Day High Use

Property	Building	Apt	Serial #	Location	Single Day High Use
Pomeroy	6705 S Lewis Ave	129	000D6F0004AD84BC	Half Bath toilet	7419.8
			Total : 69925		

Property	Building	Apt	Serial #	Location	Single Day High Use	
Read Date	Current Water Register (Gallons)	Avg Gallons Per Event	Usage Since Last Report (Gallons)	Current Events Register	Events Since Last Report	Reported?
Jan 14 2016 2:10AM	113822	3709.9	7420	1406	2	Yes
Jan 13 2016 2:09AM	106402	97.3	1459	1404	15	Yes
Jan 12 2016 2:08AM	104943	3371.4	6743	1389	2	Yes
Jan 11 2016 2:05AM	98200	505.9	1012	1387	2	Yes
Jan 10 2016 2:06AM	97188	0.0	1171	1385	0	Yes
Jan 9 2016 2:08AM	96018	0.0	0	1385	0	Yes
Jan 8 2016 2:08AM	96018	4.6	9	1385	2	Yes
Jan 7 2016 2:09AM	96008	4.7	9	1383	2	Yes
Jan 6 2016 2:08AM	95999	0.6	19	1381	31	Yes
Jan 5 2016 2:08AM	95980	4.6	485	1350	105	Yes
Jan 4 2016 2:07AM	95495	923.9	4619	1245	5	Yes
Jan 3 2016 2:09AM	90875	52.7	2002	1240	38	Yes
Jan 2 2016 2:07AM	88873	6007.3	6007	1202	1	Yes
Jan 1 2016 2:07AM	82866	1041.9	1042	1201	1	Yes
Dec 31 2015 2:07AM	81824	5425.5	5426	1200	1	Yes
Dec 30 2015 2:08AM	76398	256.4	3333	1199	13	Yes
Dec 29 2015 2:03AM	73065	13.6	1724	1186	127	Yes
Dec 28 2015 2:02AM	71341	1005.5	2011	1059	2	Yes
Dec 27 2015 2:05AM	69330	0.0	0	1057	0	Yes
Dec 26 2015 2:02AM	69330	4.7	5	1057	1	Yes
Dec 25 2015 2:08AM	69326	6514.2	6514	1056	1	Yes
Dec 24 2015 2:05AM	62812	653.3	3920	1055	6	Yes
Dec 23 2015 2:05AM	58892	0.0	7978	1049	0	Yes
Dec 22 2015 2:04AM	50914	0.0	2953	1049	0	Yes
Dec 21 2015 2:03AM	47961	75.5	2795	1049	37	Yes
Dec 20 2015 2:03AM	45167	0.0	1248	1012	0	Yes
Dec 19 2015 2:04AM	43918	3.3	7	1012	2	Yes
Dec 18 2015 2:05AM	43912	4.7	5	1010	1	Yes
Dec 17 2015 2:06AM	43907	4.6	9	1009	2	Yes
Dec 16 2015 2:04AM	43898	1007	...	Yes
			Total : 69925			

Single Day High Use

Property	Building	Apt	Serial #	Location	Single Day High Use	
Read Date	Current Water Register (Gallons)	Avg Gallons Per Event	Usage Since Last Report (Gallons)	Current Events Register	Events Since Last Report	Reported?
Pomeroy	6805 S Lewis Ave	009	000D6F0004C9D2FC	Half Bath toilet	158.9	
Jan 14 2016 2:10AM	6569	4.5	159	2550	35	Yes
Jan 13 2016 2:09AM	6410	4.5	31	2515	7	Yes
Jan 12 2016 2:08AM	6378	4.4	102	2508	23	Yes
Jan 11 2016 2:05AM	6276	4.5	45	2485	10	Yes
Jan 10 2016 2:06AM	6232	4.4	137	2475	31	Yes
Jan 9 2016 2:08AM	6094	4.4	44	2444	10	Yes
Jan 8 2016 2:08AM	6050	4.4	107	2434	24	Yes
Jan 7 2016 2:09AM	5944	4.4	49	2410	11	Yes
Jan 6 2016 2:08AM	5895	4.6	88	2399	19	Yes
Jan 5 2016 2:08AM	5807	5.0	65	2380	13	Yes
Jan 4 2016 2:07AM	5742	4.4	131	2367	30	Yes
Jan 3 2016 2:09AM	5611	4.4	62	2337	14	Yes
Jan 2 2016 2:07AM	5550	4.4	111	2323	25	Yes
Jan 1 2016 2:07AM	5439	4.4	31	2298	7	Yes
Dec 31 2015 2:07AM	5408	4.4	105	2291	24	Yes
Dec 30 2015 2:08AM	5303	4.4	57	2267	13	Yes
Dec 29 2015 2:03AM	5247	4.4	127	2254	29	Yes
Dec 28 2015 2:02AM	5119	4.4	48	2225	11	Yes
Dec 27 2015 2:05AM	5071	4.5	150	2214	33	Yes
Dec 26 2015 2:02AM	4921	4.4	53	2181	12	Yes
			Total : 2504			

Property	Building	Apt	Serial #	Location	Single Day High Use	
Dec 25 2015 2:08AM	4869	4.4	133	2169	30	Yes
Dec 24 2015 2:05AM	4735	4.4	57	2139	13	Yes
Dec 23 2015 2:05AM	4679	4.4	132	2126	30	Yes
Dec 22 2015 2:04AM	4547	4.4	74	2096	17	Yes
Dec 21 2015 2:03AM	4473	4.4	93	2079	21	Yes
Dec 20 2015 2:03AM	4380	4.3	52	2058	12	Yes
Dec 19 2015 2:04AM	4328	4.4	135	2046	31	Yes
Dec 18 2015 2:05AM	4193	4.3	22	2015	5	Yes
Dec 17 2015 2:06AM	4171	4.3	104	2010	24	Yes
Dec 16 2015 2:04AM	4067	1986	...	Yes
			Total : 2504			

Single Day High Use

Property	Building	Apt	Serial #	Location	Single Day High Use	
Pomeroy	6805 S Lewis Ave	009	000D6F0005408000	Full Bath Toilet	165.2	
Read Date	Current Water Register (Gallons)	Avg Gallons Per Event	Usage Since Last Report (Gallons)	Current Events Register	Events Since Last Report	Reported?
Jan 14 2016 2:10AM	32631	0.8	165	43607	201	Yes
Jan 13 2016 2:09AM	32466	0.8	327	43406	396	Yes
Jan 12 2016 2:08AM	32139	0.8	165	43010	200	Yes
Jan 11 2016 2:05AM	31974	0.8	327	42810	394	Yes
Jan 10 2016 2:06AM	31647	0.8	164	42416	197	Yes
Jan 9 2016 2:08AM	31484	0.8	327	42219	404	Yes
Jan 8 2016 2:08AM	31156	0.8	164	41815	201	Yes
Jan 7 2016 2:09AM	30992	0.8	330	41614	401	Yes
Jan 6 2016 2:08AM	30663	0.8	162	41213	202	Yes
Jan 5 2016 2:08AM	30501	0.8	326	41011	408	Yes
Jan 4 2016 2:07AM	30175	0.8	164	40603	207	Yes
Jan 3 2016 2:09AM	30011	0.8	325	40396	410	Yes
Jan 2 2016 2:07AM	29686	0.8	163	39986	196	Yes
Jan 1 2016 2:07AM	29523	0.8	326	39790	414	Yes
Dec 31 2015 2:07AM	29197	0.8	164	39376	207	Yes
Dec 30 2015 2:08AM	29033	0.8	328	39169	413	Yes
Dec 29 2015 2:03AM	28705	0.8	163	38756	210	Yes
Dec 28 2015 2:02AM	28542	0.8	326	38546	410	Yes
Dec 27 2015 2:05AM	28216	0.8	162	38136	202	Yes
Dec 26 2015 2:02AM	28054	0.8	321	37934	420	Yes
Dec 25 2015 2:08AM	27734	0.8	161	37514	207	Yes
Dec 24 2015 2:05AM	27572	0.8	326	37307	406	Yes
Dec 23 2015 2:05AM	27246	0.8	160	36901	201	Yes
Dec 22 2015 2:04AM	27087	0.8	318	36700	396	Yes
Dec 21 2015 2:03AM	26768	0.8	158	36304	210	Yes
Dec 20 2015 2:03AM	26611	0.8	322	36094	404	Yes
Dec 19 2015 2:04AM	26289	1.0	140	35690	139	Yes
Dec 18 2015 2:05AM	26149	0.8 (1)	72 (1)	35551	87 (1)	Yes
Dec 17 2015 2:06AM	26077	0.0	0	35464	0	No
Dec 16 2015 2:04AM	26077	35464	...	Yes
			Total : 6556			

Note 1: This value is an accumulation of multiple days worth of data due to a non reporting device. A yellow line in the above table indicates that the radio attached to this toilet did not report. This is normal. Although the radio did not report the water meter still measured and recorded the gallons and events.

Note 2: This is the first report from this device. Data is cumulative since install. These values are not used in totals. An orange line in the above table indicates that the radio attached to this toilet is was provisioned but never reported. This is normal. Although the radio did not report the water meter still measured and recorded the gallons and events.

Single Day High Use

Property	Building	Apt	Serial #	Location	Single Day High Use	
Pomeroy	6821 S Lewis Ave	041	000D6F0004C9C26E	Full Bath Toilet	335.3	
Read Date	Current Water	Avg Gallons	Usage Since	Current Events	Events Since	Reported?
			Total : 7287			

Property	Building	Apt	Serial #	Location	Single Day High Use	
	Register (Gallons)	Per Event	Last Report (Gallons)	Register	Last Report	
Jan 14 2016 2:10AM	31282	0.9	335	40102	394	Yes
Jan 13 2016 2:09AM	30947	0.8	162	39708	195	Yes
Jan 12 2016 2:08AM	30786	0.9	325	39513	378	Yes
Jan 11 2016 2:05AM	30460	0.9	162	39135	186	Yes
Jan 10 2016 2:06AM	30299	0.8	331	38949	398	Yes
Jan 9 2016 2:08AM	29967	0.8	165	38551	196	Yes
Jan 8 2016 2:08AM	29802	0.9	330	38355	386	Yes
Jan 7 2016 2:09AM	29472	0.9	164	37969	190	Yes
Jan 6 2016 2:08AM	29308	0.8	336	37779	400	Yes
Jan 5 2016 2:08AM	28972	0.9	167	37379	195	Yes
Jan 4 2016 2:07AM	28805	0.8	330	37184	397	Yes
Jan 3 2016 2:09AM	28476	0.8	163	36787	195	Yes
Jan 2 2016 2:07AM	28313	0.8	326	36592	409	Yes
Jan 1 2016 2:07AM	27987	0.8	166	36183	199	Yes
Dec 31 2015 2:07AM	27821	0.8	331	35984	405	Yes
Dec 30 2015 2:08AM	27489	0.8	170	35579	202	Yes
Dec 29 2015 2:03AM	27320	0.8	336	35377	405	Yes
Dec 28 2015 2:02AM	26983	0.9	166	34972	195	Yes
Dec 27 2015 2:05AM	26817	0.9	328	34777	378	Yes
Dec 26 2015 2:02AM	26489	0.8	168	34399	204	Yes
Dec 25 2015 2:08AM	26321	0.8	332	34195	410	Yes
Dec 24 2015 2:05AM	25989	0.8	164	33785	202	Yes
Dec 23 2015 2:05AM	25824	0.8	332	33583	405	Yes
Dec 22 2015 2:04AM	25492	0.8	162	33178	206	Yes
Dec 21 2015 2:03AM	25330	0.8	335	32972	411	Yes
Dec 20 2015 2:03AM	24996	0.8	164	32561	210	Yes
Dec 19 2015 2:04AM	24831	0.8	333	32351	415	Yes
Dec 18 2015 2:05AM	24499	0.8	169	31936	211	Yes
Dec 17 2015 2:06AM	24329	0.8	335	31725	420	Yes
Dec 16 2015 2:04AM	23994	31305	...	Yes
			Total : 7287			

Single Day High Use

Property	Building	Apt	Serial #	Location	Single Day High Use	
Pomeroy	6841 S Lewis Ave	079	000D6F0005029DDF	Full Bath Toilet	687.6	
Read Date	Current Water Register (Gallons)	Avg Gallons Per Event	Usage Since Last Report (Gallons)	Current Events Register	Events Since Last Report	Reported?
Jan 14 2016 2:10AM	72001	86.0	688	54413	8	Yes
Jan 13 2016 2:09AM	71314	16.6	1065	54405	64	Yes
Jan 12 2016 2:08AM	70249	8.5	416	54341	49	Yes
Jan 11 2016 2:05AM	69833	4.1	410	54292	101	Yes
Jan 10 2016 2:06AM	69423	0.1	58	54191	461	Yes
Jan 9 2016 2:08AM	69364	0.2	1	53730	3	Yes
Jan 8 2016 2:08AM	69364	7.3	15	53727	2	Yes
Jan 7 2016 2:09AM	69349	7.9	32	53725	4	Yes
Jan 6 2016 2:08AM	69317	158.1	316	53721	2	Yes
Jan 5 2016 2:08AM	69001	0.0	1416	53719	0	Yes
Jan 4 2016 2:07AM	67586	62.0	496	53719	8	Yes
Jan 3 2016 2:09AM	67090	33.8	1452	53711	43	Yes
Jan 2 2016 2:07AM	65638	0.0	632	53668	0	Yes
Jan 1 2016 2:07AM	65006	9.9	897	53668	91	Yes
Dec 31 2015 2:07AM	64109	0.0	691	53577	0	Yes
Dec 30 2015 2:08AM	63418	78.9	1104	53577	14	Yes
Dec 29 2015 2:03AM	62314	2.6	428	53563	165	Yes
Dec 28 2015 2:02AM	61886	770.6	1541	53398	2	Yes
Dec 27 2015 2:05AM	60345	0.0	583	53396	0	Yes
Dec 26 2015 2:02AM	59762	10.0	736	53396	74	Yes
			Total : 18486			

Property	Building	Apt	Serial #	Location	Single Day High Use	
Dec 25 2015 2:08AM	59026	2.8	285	53322	103	Yes
Dec 24 2015 2:05AM	58740	104.3	939	53219	9	Yes
Dec 23 2015 2:05AM	57801	10.7	386	53210	36	Yes
Dec 22 2015 2:04AM	57415	1.4	639	53174	457	Yes
Dec 21 2015 2:03AM	56776	7.1	21	52717	3	Yes
Dec 20 2015 2:03AM	56755	720.1	720	52714	1	Yes
Dec 19 2015 2:04AM	56035	0.0	755	52713	0	Yes
Dec 18 2015 2:05AM	55279	268.0	1340	52713	5	Yes
Dec 17 2015 2:06AM	53939	14.1	424	52708	30	Yes
Dec 16 2015 2:04AM	53515	52678	...	Yes
			Total : 18486			

Single Day High Use

Property	Building	Apt	Serial #	Location	Single Day High Use	
Pomeroy	6855 S Lewis Ave	107	000D6F0005407FFF	Full Bath Toilet	2456.2	
Read Date	Current Water Register (Gallons)	Avg Gallons Per Event	Usage Since Last Report (Gallons)	Current Events Register	Events Since Last Report	Reported?
Jan 14 2016 2:10AM	40482	0.0	2456	891	0	Yes
Jan 13 2016 2:09AM	38026	6.6	40	891	6	Yes
Jan 12 2016 2:08AM	37987	6.4	45	885	7	Yes
Jan 11 2016 2:05AM	37942	6.6	92	878	14	Yes
Jan 10 2016 2:06AM	37850	6.5	7	864	1	Yes
Jan 9 2016 2:08AM	37843	6.5	65	863	10	Yes
Jan 8 2016 2:08AM	37778	6.4	32	853	5	Yes
Jan 7 2016 2:09AM	37746	7.7	101	848	13	Yes
Jan 6 2016 2:08AM	37645	6.2	31	835	5	Yes
Jan 5 2016 2:08AM	37614	6.6	111	830	17	Yes
Jan 4 2016 2:07AM	37503	6.4	38	813	6	Yes
Jan 3 2016 2:09AM	37464	6.3	69	807	11	Yes
Jan 2 2016 2:07AM	37395	6.3	38	796	6	Yes
Jan 1 2016 2:07AM	37357	6.8	109	790	16	Yes
Dec 31 2015 2:07AM	37248	6.5	33	774	5	Yes
Dec 30 2015 2:08AM	37216	6.4	153	769	24	Yes
Dec 29 2015 2:03AM	37063	6.4	76	745	12	Yes
Dec 28 2015 2:02AM	36987	11.7	141	733	12	Yes
Dec 27 2015 2:05AM	36846	12.1	85	721	7	Yes
Dec 26 2015 2:02AM	36761	11.6	196	714	17	Yes
Dec 25 2015 2:08AM	36565	7.1	50	697	7	Yes
Dec 24 2015 2:05AM	36515	9.9	168	690	17	Yes
Dec 23 2015 2:05AM	36347	37.6	225	673	6	Yes
Dec 22 2015 2:04AM	36122	6.3	69	667	11	Yes
Dec 21 2015 2:03AM	36052	6.2	37	656	6	Yes
Dec 20 2015 2:03AM	36015	6.3	101	650	16	Yes
Dec 19 2015 2:04AM	35914	6.4	32	634	5	Yes
Dec 18 2015 2:05AM	35882	6.4	90	629	14	Yes
Dec 17 2015 2:06AM	35792	6.9	42	615	6	Yes
Dec 16 2015 2:04AM	35751	609	...	Yes
			Total : 4732			

Use with No Events

Use with No Events

Property	Building	Apt	Serial #	Location	Gallons Used	Events
Pomeroy	6855 S Lewis Ave	107	000D6F0005407FFF	Full Bath Toilet	2456.2	0
Read Date	Current Water	Avg Gallons	Usage Since	Current Events	Events Since	Reported?
			Total : 4732			

Property	Building	Apt	Serial #	Location	Gallons Used	Events
	Register(Gallons)	Per Event	Last Report (Gallons)	Register	Last Report	
Jan 14 2016 2:10AM	40482	0.0	2456	891	0	Yes
Jan 13 2016 2:09AM	38026	6.6	40	891	6	Yes
Jan 12 2016 2:08AM	37987	6.4	45	885	7	Yes
Jan 11 2016 2:05AM	37942	6.6	92	878	14	Yes
Jan 10 2016 2:06AM	37850	6.5	7	864	1	Yes
Jan 9 2016 2:08AM	37843	6.5	65	863	10	Yes
Jan 8 2016 2:08AM	37778	6.4	32	853	5	Yes
Jan 7 2016 2:09AM	37746	7.7	101	848	13	Yes
Jan 6 2016 2:08AM	37645	6.2	31	835	5	Yes
Jan 5 2016 2:08AM	37614	6.6	111	830	17	Yes
Jan 4 2016 2:07AM	37503	6.4	38	813	6	Yes
Jan 3 2016 2:09AM	37464	6.3	69	807	11	Yes
Jan 2 2016 2:07AM	37395	6.3	38	796	6	Yes
Jan 1 2016 2:07AM	37357	6.8	109	790	16	Yes
Dec 31 2015 2:07AM	37248	6.5	33	774	5	Yes
Dec 30 2015 2:08AM	37216	6.4	153	769	24	Yes
Dec 29 2015 2:03AM	37063	6.4	76	745	12	Yes
Dec 28 2015 2:02AM	36987	11.7	141	733	12	Yes
Dec 27 2015 2:05AM	36846	12.1	85	721	7	Yes
Dec 26 2015 2:02AM	36761	11.6	196	714	17	Yes
Dec 25 2015 2:08AM	36565	7.1	50	697	7	Yes
Dec 24 2015 2:05AM	36515	9.9	168	690	17	Yes
Dec 23 2015 2:05AM	36347	37.6	225	673	6	Yes
Dec 22 2015 2:04AM	36122	6.3	69	667	11	Yes
Dec 21 2015 2:03AM	36052	6.2	37	656	6	Yes
Dec 20 2015 2:03AM	36015	6.3	101	650	16	Yes
Dec 19 2015 2:04AM	35914	6.4	32	634	5	Yes
Dec 18 2015 2:05AM	35882	6.4	90	629	14	Yes
Dec 17 2015 2:06AM	35792	6.9	42	615	6	Yes
Dec 16 2015 2:04AM	35751	609	...	Yes
			Total : 4732			

© H2O Degree. All rights reserved.